



**TRANE®**

**BEYOND  
TOMORROW**

# Optimized System for Your Bottom Line

Trane Training Class  
1 Dec, 2017

# Total Cost of Ownership

Setting your system for great payback


Where is money spent over a 30 year lifetime?

|            |       |
|------------|-------|
| First Cost | 4.9%  |
| Service    | 6.6%  |
| Power      | 88.5% |



**A Balanced Approach, with a Focus on Efficiency**

# Chiller Plant Efficiency



**AVERAGE ANNUAL CHILLER PLANT EFFICIENCY IN KW/TON (C.O.P.)**  
*(Input energy includes chillers, condenser pumps, tower fans and chilled water pumping)*

Note: Based on electrically driven centrifugal chiller plants in comfort conditioning application with 5.6C nominal chilled water supply temperature and open cooling towers sized for 29.4C maximum entering condenser water temperature and 20% excess capacity

# Chiller Plant Efficiency



**Optimal  
Plant  
Efficiency**

=



**Guaranteed  
chiller  
performance**

+




**System  
application &  
control  
strategy**

# Chiller Plant Efficiency




- Major Equipment for water-cooled chiller plant
  - Chiller
  - Pump
  - Cooling Tower



# Chiller Performance

## History of Chiller Efficiency



# Chiller Performance

## BEEO Requirement (2015)

Table 6.12b : Minimum Coefficient of Performance for Chiller<sup>@2</sup> at Full Load

| Air-cooled  |                        |                |               |                |                |                |                         |                         |                         |                         |                    |               |                         |                         |                         |
|---|------------------------|----------------|---------------|----------------|----------------|----------------|-------------------------|-------------------------|-------------------------|-------------------------|--------------------|---------------|-------------------------|-------------------------|-------------------------|
| Type of compressor                                    | Reciprocating          |                | Scroll        |                | Screw          |                | VSD Screw               |                         | Centrifugal             | VSD Centrifugal         |                    |               |                         |                         |                         |
| Capacity Range (kW)                                   | Below 400 kW           | 400 kW & above | Below 400 kW  | 400 kW & above | Below 500 kW   | 500 kW & above | Below 500 kW            | 500 kW & above          | All Ratings             | All Ratings             |                    |               |                         |                         |                         |
| Minimum COP at cooling (free air flow <sup>@1</sup> ) | 2.8                    | 2.9            | 2.8           | 2.9            | 2.9            | 3.0            | 2.8 (3.6) <sup>@5</sup> | 2.9 (3.7) <sup>@5</sup> | 3.2                     | 3.1 (4.0) <sup>@5</sup> |                    |               |                         |                         |                         |
| Water-cooled  |                        |                |               |                |                |                |                         |                         |                         |                         |                    |               |                         |                         |                         |
| Type of compressor                                    | Reciprocating / Scroll |                |               | Screw          |                |                | VSD Screw               |                         |                         | Centrifugal             |                    |               | VSD Centrifugal         |                         |                         |
| Capacity Range (kW)                                   | Below 500 kW           | 500 to 1000 kW | Above 1000 kW | Below 500 kW   | 500 to 1000 kW | Above 1000 kW  | Below 500 kW            | 500 to 1000 kW          | Above 1000 kW           | Below 1000 kW           | 1000 kW to 3000 kW | Above 3000 kW | Below 1000 kW           | 1000 kW to 3000 kW      | Above 3000 kW           |
| Minimum COP (Cooling)                                 | 4.2                    | 4.7            | 5.3           | 4.8            | 5.0            | 5.5            | 4.7 (6.1) <sup>@5</sup> | 4.9 (6.3) <sup>@5</sup> | 5.2 (6.7) <sup>@5</sup> | 5.4 <sup>@3</sup>       | 5.7                | 5.8           | 5.1 (6.6) <sup>@5</sup> | 5.5 (7.1) <sup>@5</sup> | 5.6 (7.2) <sup>@5</sup> |
|   |                        |                |               |                |                |                |                         |                         | 5.6 <sup>@4</sup>       |                         |                    |               |                         |                         |                         |

Comprehensive review to be conducted in 2018, 2021 and 2024 respectively.

# Chiller Performance

## Centrifugal Chiller




Direct Drive  
(Hermetic Mech)




Multi Stage

Gear Drive  
(Hermetic Mech)



Single Stage

Gear Drive  
(Open Mech)



Single Stage

Direct Drive  
(Hermetic Mag Lev)



Multi Stage

|                                      |                                  |                                  |                                  |                                  |
|--------------------------------------|----------------------------------|----------------------------------|----------------------------------|----------------------------------|
| Type of Refrigerant                  | R-123                            | R-134a                           | R-134a                           | R-134a                           |
| Theoretical Refrigerant Efficiency   | 0.433 kW/ton<br>(8.1 COP)        | 0.460 kW/ton<br>(7.6 COP)        | 0.460 kW/ton<br>(7.6 COP)        | 0.460 kW/ton<br>(7.6 COP)        |
| Centrifugal Chiller Cycle Efficiency | 0.388 kW/ton<br>(9.1 COP)        | 0.415 kW/ton<br>(8.5 COP)        | 0.415 kW/ton<br>(8.5 COP)        | 0.415 kW/ton<br>(8.5 COP)        |
| Drive Train Efficiency               | 100%                             | 98.1%                            | 97.9%                            | 100%                             |
| Compressor Efficiency                | 83.3%                            | 80.4%                            | 81.8%                            | 78.8%                            |
| Motor Efficiency                     | 95.5%                            | 95.0%                            | 95.0%                            | 97.0%                            |
| <b>Chiller Efficiency</b>            | <b>0.487 kW/ton</b><br>(7.2 COP) | <b>0.554 kW/ton</b><br>(6.3 COP) | <b>0.545 kW/ton</b><br>(6.4 COP) | <b>0.543 kW/ton</b><br>(6.5 COP) |



# Chiller Performance

## Efficiency Comparison – Index Rating

AHRI Definition of Integrated Part Load Value (IPLV/NPLV)

$$\text{IPLV} = \frac{1\%}{A} + \frac{42\%}{B} + \frac{45\%}{C} + \frac{12\%}{D}$$

A = kW/Ton @ 29.4°C (85°F) @ 100% Load

B = kW/Ton @ 23.9°C (75°F) @ 75% Load


C = kW/Ton @ 18.3°C (65°F) @ 50% Load

D = kW/Ton @ 18.3°C (65°F) @ 25% Load

Temperatures: Expected Entering Tower Water

AHRI Conditions: Chilled Water: 54° /44° F (12.2° /6.6° C)

Condenser Water: 3 GPM/Ton (0.054 L/S/kW)



**Real World Chillers Operate at Real World Conditions**




# Chiller Performance

## Efficiency Comparison – Index Rating vs. Real-World

### Hong Kong (Two Chiller Plant)

Custom Analysis versus Generic NPLV Estimates



**Where Do The Chillers in Your Plant Run?**

# Chiller Performance

## Real Payback Require Real Analysis



**Always, Always Remember ...  
The Meter is On The BUILDING**



# Chiller Performance

## Real Payback Require Real Analysis



### TRACE™ 700

HVAC load design and analysis software



Trace Air Conditioning Economics, or TRACE™, is a design-and-analysis tool that helps HVAC professionals optimize the design of a building's heating, ventilating and air-conditioning system based on energy utilization and life-cycle cost.

A TRACE model can help establish the peak cooling and heating loads during the planning stage of a building project. At the design development stage, it aids evaluation of energy-saving concepts, such as the effects of daylighting, HVAC optimization strategies and high-performance glazing. And near the end of the construction, when the design is finalized, the TRACE model can help document compliance with ASHRAE Standard 90.1-2007/2010 or validate the building's eligibility for LEED® certification.

**Powerful modeling capabilities**

- Choose from eight load-simulation methodologies, including Heat Balance-based RTS, using algorithms provided in the latest ASHRAE Loads Toolkit. Specify either hour-by-hour (B760) or reduced-year energy/economic analysis.
- Choose from more than 500 predefined weather locations from around the globe.
- Describe building envelope and site orientation, as well as room construction, airflow, thermostat settings, heat sources and utilization schedules.
- Model various HVAC systems including single-zone, VAV-reheat, parallel fan-powered VAV, underfloor air distribution and dedicated outdoor-air systems.
- Model chillers, unitary equipment, water-source and geothermal heat pumps, boilers, electric resistance heating, gas-fired heat exchangers and air terminals.
- Include thermal storage, energy recovery, free cooling, cogeneration and district heating or cooling.
- Simulate control strategies, such as optimum start/stop, temperature or static pressure setpoint reset, humidification, night purge, fan cycling, demand-limiting and equipment sequencing.

**Compliant calculation methodologies**

TRACE 700 calculations apply techniques recommended by the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). The program is tested in compliance with ASHRAE Standard 140-2007/2011, Standard Method of Test for the Evaluation of Building Energy Analysis Computer Programs, and it meets the requirements for simulation software set by ASHRAE Standard 90.1-2007/2010 and the LEED® Green Building Rating System.

## Compliant calculation methodologies

TRACE 700 calculations apply techniques recommended by the American Society of Heating, Refrigerating and Air-Conditioning Engineers (ASHRAE). The program is tested in compliance with **ASHRAE Standard 140-2007/2011, Standard Method of Test for the Evaluation of Building Energy Analysis**

Computer Programs, and it meets the requirements for simulation software set by **ASHRAE Standard 90.1-2007/2010** and the **LEED® Green Building Rating System.**



**TRACE  
700**



**Chiller Plant  
Analyzer**

# Chiller Plant Efficiency

## Pump Performance

- Hydraulic Power  $P_{h(kW)} = q \rho g h / (3.6 \times 10^6)$ 
  - $q$  = flow capacity ( $m^3/h$ )
  - $\rho$  = density of fluid ( $kg/m^3$ )
  - $g$  = gravity ( $9.81 m/s^2$ )
  - $h$  = pump head ( $m$ )
- Pump Head is the total resistance that a pump must overcome
  - Static Head
  - Friction Head
  - Pressure Head
  - Velocity Head

# Pump Performance Pump Head Calculation



- Never oversize pump
- Select pump duty point for best efficiency

## Trane Hong Kong

Project: Air-to-Fresh Water Cooled Chiller Plant Construction  
 at Tsim Sha Tsui  
 Pump Design: DWP 1 to 4  
 Location: R/F

Flowrate: 118.00 L/s

Design Pump Head: 204 (212.8)F

Date: 07/19/09  
 Rev: 3

| Pipe Section | Location / Description | Description     | Flow Rate            | Nominal Pipe                | Flow                             | Pressure Loss                              | Pipe Length        | Equivalent                   | Velocity Pressure               | No. of pipe | Velocity Pressure | Pressure Loss | Total                                 |
|--------------|------------------------|-----------------|----------------------|-----------------------------|----------------------------------|--|--------------------|------------------------------|---------------------------------|-------------|-------------------|---------------|---------------------------------------|
|              |                        |                 | V <sub>1</sub> (L/s) | Size<br>D <sub>1</sub> (mm) | Velocity<br>v <sub>1</sub> (m/s) | per Unit Length<br>μ <sub>1</sub> (Pa/100) | L <sub>1</sub> (m) | Length<br>L <sub>2</sub> (m) | Loss Factor for<br>Fitting<br>K | Loss (Pa)   | n (No.)           | Loss (Pa)     | Accumulative<br>Pressure Loss<br>(Pa) |
| 1-2          | R/F CHWP               | Pump Discharge  | 118                  | 250                         | 2.41                             | 160  | 3                  | —                            | —                               | —           | —                 | —             | —                                     |
|              |                        | Pipe            | 118                  | 250                         | 2.41                             | 160  | —                  | —                            | —                               | 0.48        | 0.48              | 0.48          |                                       |
|              |                        | Isolating Valve | 118                  | 250                         | 2.41                             | 160  | —                  | —                            | —                               | 1           | 0.56              | 0.56          |                                       |
|              |                        | Check Valve     | 118                  | 250                         | 2.41                             | 160  | —                  | —                            | —                               | 1           | 2.00              | 2.00          |                                       |
|              |                        | 90 deg Elbow    | 118                  | 250                         | 2.41                             | 160  | —                  | 17                           | 0.3                             | 1           | 0.82              | 0.82          |                                       |
| Flange Joint | 118                    | 250             | 2.41                 | 160                         | —                                | 17   | 0.1                | 1                            | 0.27                            | 0.27        |                   |               |                                       |
| 2-3          | R/F                    | Pipe            | 354                  | 400                         | 2.82                             | 160  | 12.5               | —                            | —                               | 2.00        | 2.00              | 7.63          |                                       |
|              |                        | 45 deg elbow    | 354                  | 400                         | 2.82                             | 160  | —                  | 20                           | 0.21                            | 2           | 1.05              | 1.05          |                                       |
|              |                        | 90 deg elbow    | 354                  | 400                         | 2.82                             | 160  | —                  | 20                           | 0.3                             | 1           | 1.39              | 1.39          |                                       |
|              |                        | Tee in          | 354                  | 400                         | 2.82                             | 160  | —                  | 20                           | 0.3                             | 3           | 4.18              | 4.18          |                                       |
|              |                        | Tee out         | 354                  | 400                         | 2.82                             | 160  | —                  | 20                           | 0.51                            | 1           | 2.37              | 2.37          |                                       |
| Reducer      | 354                    | 400             | 2.82                 | 160                         | —                                | 20   | 0.3                | 1                            | 1.39                            | 1.39        |                   |               |                                       |
| 3-4          | R/F                    | Pipe            | 236                  | 300                         | 3.34                             | 240  | 12.1               | —                            | —                               | 2.00        | 2.00              | 21.33         |                                       |
|              |                        | 45 deg elbow    | 236                  | 300                         | 3.34                             | 240  | —                  | 22                           | 0.2                             | 2           | 2.11              | 2.11          |                                       |
|              |                        | 90 deg elbow    | 236                  | 300                         | 3.34                             | 240  | —                  | 22                           | 0.3                             | 1           | 1.58              | 1.58          |                                       |
|              |                        | Tee out         | 236                  | 300                         | 3.34                             | 240  | —                  | 22                           | 0.51                            | 1           | 2.69              | 2.69          |                                       |
|              |                        | Reducer         | 236                  | 300                         | 3.34                             | 240  | —                  | 22                           | 0.3                             | 1           | 1.39              | 1.39          |                                       |
| 4-5          | R/F                    | Pipe            | 118                  | 250                         | 2.41                             | 160  | 8                  | —                            | —                               | 0.96        | 0.96              | 28.38         |                                       |
|              |                        | Isolating Valve | 118                  | 250                         | 2.41                             | 160  | —                  | —                            | —                               | 3           | 1.74              | 1.74          |                                       |
|              |                        | Flange Joint    | 118                  | 250                         | 2.41                             | 160  | —                  | 17                           | 0.1                             | 2           | 0.54              | 0.54          |                                       |
|              |                        | 90 deg Elbow    | 118                  | 250                         | 2.41                             | 160  | —                  | 17                           | 0.3                             | 4           | 3.26              | 3.26          |                                       |
|              |                        | Tee in          | 118                  | 250                         | 2.41                             | 160  | —                  | 11                           | 0.7                             | 1           | 2.04              | 2.04          |                                       |
| 5-6          | R/F                    | Pipe            | 236                  | 300                         | 3.34                             | 240  | 11                 | —                            | —                               | 2.04        | 2.04              | 38.38         |                                       |
|              |                        | 45 deg elbow    | 236                  | 300                         | 3.34                             | 240  | —                  | 22                           | 0.2                             | 2           | 2.11              | 2.11          |                                       |
|              |                        | 90 deg elbow    | 236                  | 300                         | 3.34                             | 240  | —                  | 22                           | 0.3                             | 1           | 1.58              | 1.58          |                                       |
|              |                        | Tee in          | 236                  | 300                         | 3.34                             | 240  | —                  | 22                           | 0.51                            | 1           | 4.49              | 4.49          |                                       |
|              |                        | Reducer         | 236                  | 300                         | 3.34                             | 240  | —                  | 22                           | 0.3                             | 1           | 1.92              | 1.92          |                                       |
| 6-7          | R/F                    | Pipe            | 354                  | 400                         | 2.82                             | 160  | 12                 | —                            | —                               | 2.04        | 2.04              | 47.80         |                                       |
|              |                        | Isolating Valve | 354                  | 400                         | 2.82                             | 160  | —                  | —                            | —                               | 20          | 0.2               | 1             | 0.93                                  |
|              |                        | Flange Joint    | 354                  | 400                         | 2.82                             | 160  | —                  | 20                           | 0.21                            | 2           | 1.92              | 1.92          |                                       |
|              |                        | 45 deg elbow    | 354                  | 400                         | 2.82                             | 160  | —                  | 20                           | 0.3                             | 2           | 2.78              | 2.78          |                                       |
|              |                        | Tee in          | 354                  | 400                         | 2.82                             | 160  | —                  | 20                           | 0.3                             | 2           | 2.78              | 2.78          |                                       |
| 7-8          | Cooling Tower          | Pipe            | 118                  | 250                         | 2.41                             | 160  | 7                  | —                            | —                               | 1.12        | 1.12              | 51.65         |                                       |
|              |                        | 90 deg elbow    | 118                  | 250                         | 2.41                             | 160  | —                  | 17                           | 0.3                             | 3           | 2.47              | 2.47          |                                       |
|              |                        | Isolating Valve | 118                  | 250                         | 2.41                             | 160  | —                  | 17                           | 1.11                            | 1           | 1.62              | 1.62          |                                       |
|              |                        | Flange Joint    | 118                  | 250                         | 2.41                             | 160  | —                  | 17                           | —                               | 1           | 0.58              | 0.58          |                                       |
|              |                        | 90 deg Elbow    | 118                  | 250                         | 2.41                             | 160  | —                  | 17                           | —                               | 1           | 2.16              | 2.16          |                                       |
| 8-9          | R/F                    | Pipe            | 90                   | 150                         | 3.34                             | 240  | —                  | 11                           | 0.55                            | 2           | 1.87              | 1.87          |                                       |
|              |                        | Isolating Valve | 118                  | 250                         | 2.41                             | 160  | —                  | —                            | —                               | 2           | 0.56              | 0.56          |                                       |
|              |                        | Flange Joint    | 118                  | 250                         | 2.41                             | 160  | —                  | —                            | —                               | 2           | 1.18              | 1.18          |                                       |
|              |                        | 90 deg elbow    | 118                  | 250                         | 2.41                             | 160  | —                  | 17                           | 0.3                             | 3           | 2.45              | 2.45          |                                       |
|              |                        | Tee in          | 354                  | 400                         | 2.82                             | 160  | —                  | 20                           | 0.4                             | 3           | 1.23              | 1.23          |                                       |
| 9-10         | R/F                    | Pipe            | 354                  | 400                         | 2.82                             | 160  | —                  | —                            | —                               | 2           | 1.18              | 65.42         |                                       |
|              |                        | 90 deg Elbow    | 354                  | 400                         | 2.82                             | 160  | —                  | 20                           | 0.3                             | 1           | 1.39              | 78.38         |                                       |
|              |                        | Tee in          | 354                  | 400                         | 2.82                             | 160  | —                  | 20                           | 0.4                             | 3           | 4.57              | 78.74         |                                       |
|              |                        | Tee out         | 354                  | 400                         | 2.82                             | 160  | —                  | 20                           | 0.6                             | 4           | 11.14             | 89.87         |                                       |
|              |                        | Reducer         | 354                  | 400                         | 2.82                             | 160  | —                  | 20                           | 0.3                             | 1           | 1.39              | 101.11        |                                       |
| 10-1         | R/F                    | Pipe            | 118                  | 250                         | 2.41                             | 160  | 1.5                | —                            | —                               | 0.24        | 0.24              | 102.41        |                                       |
|              |                        | Isolating Valve | 118                  | 250                         | 2.41                             | 160  | —                  | —                            | —                               | 1           | 0.58              | 102.99        |                                       |
|              |                        | Flange Joint    | 118                  | 250                         | 2.41                             | 160  | —                  | 17                           | 0.3                             | 1           | 0.82              | 103.81        |                                       |
|              |                        | 90 deg Elbow    | 118                  | 250                         | 2.41                             | 160  | —                  | 17                           | 0.3                             | 1           | 0.82              | 104.63        |                                       |
|              |                        | Flange Joint    | 118                  | 250                         | 2.41                             | 160  | —                  | 17                           | 0.1                             | 1           | 0.27              | 104.08        |                                       |

Equation:  
 1. Velocity = (m/s) = (V / 1000) \* (1.483 \* 10<sup>-10</sup> \* D<sup>-5</sup>)<sup>0.5</sup>  
 2. Velocity Pressure Loss = (Pa) = (ρ \* V<sup>2</sup>) \* (n) \* (L) \* 1000

- Notes:  
 1. The pump head calculation is according to "CRBSE Guide C" Section 4: Flow of Fluid in Pipes and Ducts.  
 2. Values of Equivalent length of pipe, L<sub>2</sub>, and Pressure loss per unit length μ<sub>1</sub> are extracted from "CRBSE Guide C" Table 4.17  
 3. Value of Velocity pressure loss factor of fitting K<sub>2</sub> is extracted from "CRBSE Guide C" Section 4.9

Subtotal (100% Safety Factor) 126.00  
 Chiller Pressure Drop 88.40  
 Static Pressure 48.35  
 Total (HPa) 262.75



# Pump Performance

## Reduce Friction Loss





# Pump Performance

## Pump Head Calculation – BEC 2015

### BEC 2015 Chapter 6 Energy Efficiency Requirements for Air-conditioning Installation


#### 6.9 Frictional Loss of Water Piping System

6.9.1 Water piping with diameter 50 mm or below should be sized for water flow velocity not exceeding 1.2 m/s.

6.9.2 Water piping with diameter larger than 50 mm should be sized for frictional loss not exceeding 400 Pa/m and –

- (a) water flow velocity not exceeding 2.5 m/s for system that operates under non-variable flow condition; or
- (b) water flow velocity not exceeding 3.0 m/s for system that operates under variable flow condition.

- Pressure drop per unit length
  - 2.5m/s @ 200mm pipe
  - 240 Pa/m with 89.7kg/s



SEAMLESS STEEL (S30400)  
WATER AT 10 °C

| Pipe dia. (mm) | Flow rate (kg/s) | Velocity (m/s) | Frictional loss (Pa/m) |
|----------------|------------------|----------------|------------------------|
| 15             | 0.10             | 0.80           | 1.00                   |
| 20             | 0.15             | 0.75           | 0.60                   |
| 25             | 0.20             | 0.70           | 0.40                   |
| 32             | 0.25             | 0.65           | 0.30                   |
| 40             | 0.30             | 0.60           | 0.25                   |
| 50             | 0.35             | 0.55           | 0.20                   |
| 63             | 0.40             | 0.50           | 0.18                   |
| 80             | 0.45             | 0.45           | 0.15                   |
| 100            | 0.50             | 0.40           | 0.12                   |
| 125            | 0.55             | 0.35           | 0.10                   |
| 150            | 0.60             | 0.30           | 0.08                   |
| 200            | 0.70             | 0.25           | 0.05                   |
| 250            | 0.80             | 0.20           | 0.04                   |
| 300            | 0.90             | 0.15           | 0.03                   |
| 350            | 1.00             | 0.12           | 0.02                   |
| 400            | 1.10             | 0.10           | 0.02                   |
| 450            | 1.20             | 0.08           | 0.01                   |
| 500            | 1.30             | 0.07           | 0.01                   |
| 600            | 1.50             | 0.05           | 0.01                   |
| 700            | 1.70             | 0.04           | 0.01                   |
| 800            | 1.90             | 0.03           | 0.01                   |
| 900            | 2.10             | 0.03           | 0.01                   |
| 1000           | 2.30             | 0.02           | 0.01                   |

CIBSE Guide C4  
Flow of Fluids in Pipes and Ducts




# Pump Performance

## Pump Head Calculation




- Friction Losses in Elbow (equiv. length)
  - 18 Feet (90° Elbow)
- Pressure drop
  - $18 / 3.3 \times 240 \text{ Pa/m}$
  - $= 1.309 \text{ kPa}$
- Pump Power Consumption
  - $1.309 \times 89.7 / 0.7 / 0.93 / 1,000$
  - $= 0.18 \text{ kW}$
- Annual Operation Cost
  - $0.18 \times 12 \times 365 \times 1.2$
  - $= \text{HKD}946$



# Pump Performance


## Pump Head Calculation

- Friction Losses in Elbow (equiv. length)
  - 10 Feet (45° Elbow)
  - 18 Feet (90° Elbow)
- Pressure drop difference
 
$$(18-10) / 3.3 \times 240 \text{ Pa/m} \times 2 = 1,164 \text{ Pa} = 1.164 \text{ kPa}$$
- Pump Power Consumption
 
$$1.164 \times 89.7 / 0.7 / 0.93 / 1,000 = 0.16 \text{ kW}$$
- Annual Operation Cost
 
$$0.16 \times 12 \times 365 \times 1.2 = \text{HKD}841$$



# Pump Performance

## Reduce Friction Loss



# Pump Performance

## Reduce Friction Loss



# Pump Performance

## Reduce Friction Loss






# Pump Performance

## Reduce Friction Loss



# Pump Performance

## Reduce Friction Loss



Optimal chiller plant layout and careful selection of low pressure drop devices reduces pressure losses

# Pump Performance

## Simplify Piping Layout

- Friction Loss in 100% open balancing valve
  - Nominal Size: 200mm
  - Flow Rate: 89.7l/s
  - Pressure drop = 17.8kPa
- Pump Power Consumption
$$17.8 \times 89.7 / 0.7 / 0.93 / 1,000$$
$$= 2.45 \text{ kW}$$
- Annual Operation Cost
$$2.45 \times 12 \times 365 \times 1.2$$
$$= \text{HKD}12,877$$




# Pump Performance

## Simplify Piping Layout

Water-cooled chiller

Condensing water pump




Chilled water pump

Cooling tower

Water tank

# Pump Performance

## Simplify Piping Layout



### Apply low friction loss fitting

- Reduce overall pressure drop

### Equal pipe length for self-balancing

- Eliminate balancing equipment



# Pump Performance

## Reduce Friction Loss

- Increase the pipe diameter of the system
- Minimize the length of the piping in the system
- Simplifying the layout as much as possible
- Minimize the number of elbows, tees, valves, fittings and other obstructions in the piping system
- Reduce the flow rate

# Cool More or Pump More?


- Pump efficiency  $\approx 70\%$   
**COP  $\approx 0.7$**
- Chiller COP  $\approx 7.0$
- Chiller COP  $\approx 10x$  the pump COP

**Conclusion:**  
**work your most efficient equipment harder**

# System Enhancement

## Earthwise Application


- Low Flow
- Low Temperature
- High Efficiency Systems




# System Enhancement

## Earthwise Application


Supply temperature




Temperature differential




Flow rates




Fans



Ductwork



Pump





Piping




# System Enhancement

## Why Consider Variable Primary Flow (VPF) Now?

- Chiller control sophistication
- Operating cost savings
  - Pump energy
  - Response to low  $\Delta T$  Syndrome




### Variable Primary design



# Variable Primary Flow (VPF)

## Advantages

- Reduces capital investment
- Saves mechanical-room space
- Simplifies control
- Improves system reliability
- Improved chiller performance






# Variable Primary Flow (VPF)

Improve chiller performance



CenTraVac Part Load Performance CTV-1  
% Load vs. kW/ton -- using ARI Relief Method




Version 24.08, REVL 55066

# Variable Primary Flow (VPF)

## Improve chiller performance

CenTraVac Part Load Performance CTV-1  
 % Load vs. kW/ton -- using Constant Condenser Method




# Variable Primary Flow (VPF)

## Three Key Application Requirements

- Chillers must be able to accommodate a change of flow of at least 10% per minute; 30% or even 50% is even better
- Minimum and maximum flows must not be violated
- A bypass is required to maintain minimum flow

# Chiller-Tower Optimization (CTO)

## Optimal condenser water control



# Chiller-Tower Optimization (CTO)


## Dependent On?

- Chilled water plant
  - Tower design
  - Chiller design
    - Centrifugal
    - Helical rotary
    - Variable speed drive
    - Absorption
  - Changing conditions
    - Chiller load
    - Ambient wet bulb




# System Enhancement

- EarthWise Application
  - Low flow, low temperature and large  $\Delta T$  system
- Variable Primary Flow
- Chiller-tower Optimization



# Energy Approach




# PERFORMANCE MANAGEMENT

# Energy Approach

## Baseline Energy Consumption



### Electricity Fee






# Energy Approach

## Strategies for chiller upgrades & optimization



- Correctly Size the New Equipment
- Proper Chiller plant design
  - System Schematic
  - Layout
- Implement of Chiller Plant Control



# Energy Approach

## Correctly Size the New Equipment

- Determine actual building load
  - From BMS/operation log
  - Estimated from electric bill




**Electricity Fee for Chiller Plant = HKD5,662,191 (65% of overall)**

# Energy Approach

## Correctly Size the New Equipment


- Determine actual building load
  - From BMS/operation log
  - Estimated from electric bill
- Downsize Chiller if possible
  - Match with cooling load profile
  - Reduce initial cost and payback period
- Replace with higher efficiency chiller
  - Improve overall savings



# Energy Approach


## Correctly Size the New Equipment

- Energy Analysis
  - Employ TRACE 700 Chiller Plant Analyzer for plant configuration comparisons
  - Input existing energy profile for analysis
  - Calculate the energy and economic effects on different configuration



# Energy Approach

## Correctly Size the New Equipment



# Energy Approach

## Correctly Size the New Equipment


- Alternative 1
  - 2 no 600 TR water-cooled centrifugal chiller
  - 1 no 600 TR water-cooled centrifugal chiller c/w AFD
- Alternative 2
  - 2 no 750 TR water-cooled centrifugal chiller
  - 1 no 300 TR water-cooled screw chiller

**Total 1,800TR cooling capacity will be provided**

# Energy Approach


## Correctly Size the New Equipment

### Alternative 1



**Annual Saving:**  
**HKD 2,287,377 (40%)**

### Alternative 2



**Annual Saving:**  
**HKD 2,084,079 (36.6%)**

# Energy Approach


## Chiller Plant Design (Schematic)

- Review of Existing System Arrangement
- Consideration of System Change-over / Migration
- Select chilled / condensing water distribution system
- Decide equipment design condition  
(e.g. Chilled Water Temp, Cooling Tower Approach)
- Properly size pipe sizes
- Associated system design  
(e.g. Make-up / bleed off system, chemical treatment system)



# Energy Approach

## Chiller Plant Design (Schematic)




# Energy Approach

## Chiller Plant Design (Layout)


- Satisfy statutory requirement
- Sufficient space for maintenance and service
- Minimize water pressure drop

# Energy Approach

## Chiller Plant Design (Layout)



# Energy Approach Chiller Plant Control





Comprehensive control system with Cooling Tower Optimization

# Energy Approach

## Chiller Plant Control

- Fully Automation
- Trend log for major equipment
- Alarm Management

| Time                | Description                   | Status  | Action |
|---------------------|-------------------------------|---------|--------|
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |
| 01/22/2011 10:10:00 | 000000 - Communication Status | Warning | ...    |

# Energy Approach

## Summary

- System analysis for plant configuration design
- Select high efficiency for better energy saving
- Consider pressure drop and future maintenance during pipework and layout design
- Reliable Chiller Plant Control System
- Monitor the system performance after installation



***TRANE***<sup>®</sup>